

TABLE FOR SELECTING THE LENGTH AND NUMBER OF WRAPS OF PIRO MULTITUBE PM FOR PLASTIC PIPES IN MINERAL WOOL INSULATION

PP-R Stabi AL / PP-R/GF/PP-R PIPES							
	Select the dimension and number of rows of Piro Multitube PM			FLOOR CLASS EI 180 width from 150 mm and density 1700 kg/m ³		WALL CLASS EI 180 width from 150 mm and density 600 kg/m ³	
				Insulation thickness 25 mm			
The outer diameter of the flammable pipe	Piro Multitube PM width selected from ETA	Piro Multitube PM thickness selected from ETA	Number of rows of the Piro Multitube PM	Number of Piro Multitube PM wraps in one row	Total length of the Piro Multitube PM to be cut off	Number of Piro Multitube PM wraps in one row	Total length of the Piro Multitube PM to be cut off
mm	mm	mm			mm		mm
15	60	2,5	2	4	691	4	691
	60	4	1	4	440	4	440
	100	4,8	1	2	185	2	185
25	60	2,5	2	4	942	4	942
	60	4	1	4	565	4	565
	100	4,8	1	2	247	2	247
32	60	2,5	2	4	1118	4	1118
	60	4	1	4	653	4	653
	100	4,8	1	2	291	2	291
40	60	2,5	2	4	1319	4	1319
	60	4	1	4	754	4	754
	100	4,8	1	2	342	2	342
50	60	2,5	2	4	1570	4	1570
	60	4	1	4	879	4	879
	100	4,8	1	2	404	2	404
63	60	2,5	2	4	1897	4	1897
	60	4	1	4	1042	4	1042
	100	4,8	1	2	486	2	486
75	60	2,5	2	4	2193	4	2193
	60	4	1	4	1193	4	1193
	100	4,8	1	2	561	2	561
83	60	2,5	2	4	2399	4	2399
	60	4	1	4	1294	4	1294
	100	4,8	1	2	612	2	612
90	60	2,5	2	4	2575	4	2575
	60	4	1	4	1382	4	1382
	100	4,8	1	2	656	2	656
110	60	2,5	2	4	3077	4	3077
	60	4	1	4	1633	4	1633
	100	4,8	1	2	781	2	781