

THE SEALING OF EXPANSION JOINTS IN WALLS AND FLOORS AND BETWEEN WALLS AND FLOORS

Type of expansion joint	Protection	Expansion joint width		PiroAcrylic Sealant AC120		EI classification		ETA-17/1059
		mm	mm	floor - floor floor - wall	wall - wall			
Vertical, horizontal	Mineral wool one side	60	2,5/3			EI 120-V-T-X-B-W60	1	
Vertical, horizontal	Mineral wool j one side	100	1,6			EI 120-V-T-X-B-W100	3	
Vertical, horizontal	Mineral wool both sides	60	0,4			EI 120-V-T-X-B-W60	2	
Floor, between floor and wall	Mineral wool one side	60	0,6/1,2	EI 120-H-T-X-B-W60			4	
Floor, between floor and wall	Mineral wool one side top	100	1,6	EI 120-H-T-X-B-W100			5	
Floor, between floor and wall	Mineral wool one side bottom	100	1,6	EI 120-H-T-X-B-W100			6	