



Reg. No. 041/P-007

NOTIFIED BODY 1396
Osloboditeľov 282, 059 35 Batizovce, Slovakia
Tel.+421 52 285 1611, www.fires.sk



Certificate of constancy of performance

1396-CPR-0199

In compliance with Regulation (EU) No 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction products Regulation or CPR), this certificate applies to the construction product

Flame Stal® Fireproof Solvent

a reactive intumescent coating system used as fire protection of open sections (e.g. type I, H), rectangular hollow beams and circular/rectangular hollow columns up to fire resistance classification R60-IncSlow, on conditions defined in Assessment and verification of constancy of performance C1396/21/0006/4001/SC (issued by FIRES, s.r.o., NB 1396 on 23. 03. 2021). The product is

placed on the market under the name or trade mark of

**Pirosystem Sp. z o.o.
Ogrodnicza 3A, 83-021 Wiślina, Poland**

and produced in the manufacturing plant

code 111

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in the

ETA 20/0957 of 22/03/2021

and

EAD 350402-00-1106: 2017

under system 1 for the performance set out in the ETA are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on 23. 03. 2021 and will remain valid as long as neither the ETA, the EAD, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Batizovce, 23. 03. 2021

124964

FIRES 136b/C-24/08/2016-E



Ing. Henrieta Lapková
Head of Product Certification Body