



**INSTYTUT TECHNIKI BUDOWLANEJ**  
PL 00-611 WARSZAWA  
ul. Filtrowa 1  
tel.: (+48 22) 825-04-71  
(+48 22) 825-76-55  
fax: (+48 22) 825-52-86  
[www.itb.pl](http://www.itb.pl)



Member of



[www.eota.eu](http://www.eota.eu)

## European Technical Assessment

**ETA-17/1064  
of 14/12/2017**

### General Part

**Technical Assessment Body issuing the European Technical Assessment**

Instytut Techniki Budowlanej

**Trade name of the construction product**

Piro Wrap PW

**Product family to which the construction product belongs**

Fire Stopping and Fire Sealing Products.  
Penetration Seals

**Manufacturer**

PIROSYSTEM Sp. z o.o.  
ul. Ogrodnicza 3A  
83-021 Wiślina  
Poland

**Manufacturing plant**

Manufacturing plant no. 1

**This European Technical Assessment contains**

21 pages including 3 Annexes which form an integral part of this Assessment

**This European Technical Assessment is issued in accordance with regulation (EU) No 305/2011, on the basis of**

Guideline for European Technical Approval  
"Fire Stopping and Fire Sealing Products – Part 2: Penetration Seals" ETAG 026-2, edition August 2011, used as European Assessment Document (EAD)

*This European Technical Assessment is issued by the Technical Assessment Body in its official language. Translations of this European Technical Assessment in other languages shall fully correspond to the original issued document and shall be identified as such.*

*Communication of this European Technical Assessment, including transmission by electronic means, shall be in full. However, partial reproduction may only be made with the written consent of the issuing Technical Assessment Body. Any partial reproduction has to be identified as such.*

## **Specific Part**

### **1 Technical description of the product**

Piro Wrap PW is an intumescent wrap pipe closure device used to form penetration seals where combustible pipes penetrate walls and floors.

Piro Wrap PW wraps are supplied in assembled form. They include one or more layers of an intumescent liner, graphite based, inserted into an outer layer made of PVC foil or similar material.

Piro Wrap PW shall be wrapped around the pipe and may be cut to a required length (equal or greater than external circumference of the pipe), if necessary. They shall be pushed into the aperture in the separating element.

### **2 Specification of the intended use in accordance with the applicable European Assessment Document (EAD)**

#### **2.1 Intended use**

The intended use of Piro Wrap PW is to reinstate the fire resistance performance of rigid wall and rigid floor constructions where they are penetrated by combustible pipes.

The specific elements of construction that the Piro Wrap PW may be used to provide a penetration seal in, are as follows:

Rigid walls: The wall must have a minimum thickness of 150 mm and comprise concrete, reinforced concrete, aerated concrete, ceramic brick, cavity brick or checker brick, with a minimum density of 600 kg/m<sup>3</sup>.

Rigid floors: The floor must have a minimum thickness of 150 mm and comprise concrete or reinforced concrete with a minimum density of 1700 kg/m<sup>3</sup>.

The supporting construction shall be classified in accordance with EN 13501-2 for the required fire resistance period (equal or greater than specified in Annex B).

Piro Wrap PW may be used to provide a penetration seal with specific combustible pipes (according to Annexes A to C).

The Piro Wrap PW shall be either placed in the centre of the wall thickness (according to Annex B1) or in the distance of 10 mm from the bottom of the floor (according to Annex B3).

The minimum distance between the penetration seals in supporting construction shall be 100 mm.

Pipes shall be supported at maximum 370 mm away from both faces of the wall constructions and from the upper face of floor constructions.

The performances given in this European Technical Assessment are based on an assumed working life of the Piro Wrap PW of 10 years. The indications given on the working life cannot be interpreted as a guarantee given by the producer or the

Technical Assessment Body, but are to be regarded only as a means for choosing the right products in relation to the expected economically reasonable working life of the works.

## **2.2 Use category**

Type Z<sub>2</sub>: intended for use in internal conditions with humidity lower than 85% RH, excluding temperatures below 0°C, without exposure to rain or UV.

## **3 Performance of the product and references to the methods used for its assessment**

### **3.1 Performance of the product**

#### **3.1.1 Safety in case of fire (BWR 2)**

| <b>Essential characteristic</b> | <b>Performance</b> |
|---------------------------------|--------------------|
| Reaction to fire                | Class F            |
| Resistance to fire              | See Annex B        |

#### **3.1.2 Hygiene, health and the environment (BWR 3)**

The applicant has submitted a written declaration that the product and/or constituents of the product contains no substances which have been classified as dangerous according to EOTA TR 034.

Regarding the dangerous substances clauses contained in this European Technical Assessment, there may be requirements applicable to the products falling within its scope (e.g. transposed European legislation and national laws, regulations and administrative provisions). In order to meet the provisions of the Construction Products Regulation, these requirements need also to be complied with, when and where they apply.

#### **3.1.3 Safety and accessibility in use (BWR 4)**

No performance assessed.

#### **3.1.4 Protection against noise (BWR 5)**

No performance assessed.

#### **3.1.5 Energy economy and heat retention (BWR 6)**

No performance assessed.

### 3.1.6 General aspects relating to fitness for use

| Essential characteristic      | Performance                       |
|-------------------------------|-----------------------------------|
| Durability and serviceability | Use category: Type Z <sub>2</sub> |

### 3.1.7 Sustainable use of natural resources (BWR 7)

No performance assessed.

### 3.2 Methods used for the assessment

The assessment of fitness of the wrap for the declared intended use in relation to the requirements for safety in case of fire and general aspects relating to fitness for use has been made in accordance with the ETAG 026-2 *"Fire Stopping and Fire Sealing Products – Part 2: Penetration Seals"*, edition August 2011.

## 4 Assessment and verification of constancy of performance (AVCP) system applied, with reference to its legal base

According to Decision 99/454/EC of the European Commission, as amended by Decision 2001/596/EC of the European Commission the system 1 of assessment and verification of constancy of performance applies (see Annex V to Regulation (EU) No 305/2011).

## 5 Technical details necessary for the implementation of the AVCP system, as provided in the applicable European Assessment Document (EAD)

Technical details necessary for the implementation of the AVCP system are laid down in the control plan deposited in Instytut Techniki Budowlanej.

For type testing the results of the tests performed as part of the assessment for the European Technical Assessment shall be used unless there are changes in the production line or plant. In such cases the necessary type testing has to be agreed between Instytut Techniki Budowlanej and the notified body.

Issued in Warsaw on 14/12/2017 by Instytut Techniki Budowlanej

  
Anna Panek, MSc  
Deputy Director of ITB



## Additional provisions

- Classification given in tables B2.1 and B4.1 is valid for pipes made from PE-HD according to EN 1519-1 or EN 12666-1, pipes made from PE according to EN 12201-2, EN 1519-1 and EN 12666-1, pipes made from ABS according to EN 1455-1 and pipes made from SAN + PVC according to EN 1565-1.
- Classification given in tables B2.2 and B4.2 is valid for pipes made from PP according to EN 1451-1.
- Classification given in tables B2.3 and B4.3 is valid for pipes made from PVC-U according to EN 1329-1, EN 1453-1 or EN 1452-1, pipes made from PVC-C according to EN 1566-1.

## Table of contents (Annexes B and C):

### Annex B: Construction details and resistance to fire classification


|  |   |
|--|---|
| Annex B1: Plastic pipe penetration seal in rigid wall .....  | 7 |
| Annex B3: Plastic pipe penetration seal in rigid floor ..... | 9 |

### Annex C: Ranges of pipes diameter, pipes wall thicknesses and intumescent material thickness

|   |    |
|---|----|
| Fig. 1. Range of PE-HD / PE / ABS / SAN + PVC pipes in penetration seal<br>(according to Annex B1) .....  | 11 |
| Fig. 2. Range of intumescent material thickness for PE-HD / PE / ABS / SAN + PVC pipes<br>in penetration seal (according to Annex B1) .....                       | 12 |
| Fig. 3. Range of intumescent material thickness for PE-HD / PE / ABS / SAN + PVC pipes<br>in penetration seal (according to Annex B1) .....                       | 13 |
| Fig. 4. Range of intumescent material thickness for PP pipes in penetration seal<br>(according to Annex B1) .....   | 14 |
| Fig. 5. Range of PVC-U / PVC-C pipes in penetration seal (according to Annex B1) .....  | 15 |
| Fig. 6. Range of intumescent material thickness for PVC-U / PVC-C pipes<br>in penetration seal (according to Annex B1) .....                                      | 16 |
| Fig. 7. Range of PE-HD / PE / ABS / SAN + PVC pipes in penetration seal<br>(according to Annex B3) .....  | 17 |
| Fig. 8. Range of intumescent material thickness for PVC-U / PVC-C, PE-HD / PE / ABS /<br>SAN + PVC and PP pipes in penetration seal (according to Annex B3) ..... | 18 |
| Fig. 9. Range of intumescent material thickness for PVC-U / PVC-C, PE-HD / PE / ABS /<br>SAN + PVC and PP pipes in penetration seal (according to Annex B3) ..... | 19 |
| Fig.10. Range of PP pipes in penetration seal (according to Annex B3) .....   | 20 |
| Fig.11. Range of PVC-U / PVC-C pipes in penetration seal (according to Annex B3) .....  | 21 |

|                              |  |
|------------------------------|--|
| <b>Piro Wrap PW</b>          | <b>Annex A</b><br>of European<br>Technical Assessment<br>ETA-17/1064 |
| <b>Additional provisions</b> |  |

**Plastic pipe penetration seal in rigid wall, made with use of Piro Wrap PW.**



- 1 rigid wall thickness of  $B \geq 150$  mm
- 2 plastic pipe, diameter  $\varnothing$ , pipe wall thickness  $t$
- 3 Piro Wrap PW [ $l \times g$ ] mm, placed in the centre of the wall thickness
- 4 space between the pipe and supporting construction filled with cement mortar,  $u \leq 25$  mm

**Piro Wrap PW**

**Construction details**  
Plastic pipe penetration seal in rigid wall

**Annex B1**  
of European  
Technical Assessment  
ETA-17/1064

**Resistance to fire classification of plastic pipes penetration seals in rigid wall, made with use of Piro Wrap PW, in accordance with Annex B1.**

**Table B2.1 PE-HD / PE / ABS / SAN + PVC pipes**

| Pipe material                    | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|----------------------------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|                                  |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PE-HD /<br>PE / ABS /<br>SAN+PVC | ≤ 40                  | 2.4                         | 60                   | 2.0                   | EI 120 U/C<br>EI 120 C/C |
|                                  | ≤ 50                  | 3.5                         | 60                   | see fig. 2 in Annex C |                          |
|                                  | 40 < Ø ≤ 160          | see fig. 1 in Annex C       | 100                  | see fig. 3 in Annex C |                          |
|                                  |                       | see fig. 1 in Annex C       | 100                  | see fig. 3 in Annex C | EI 90 U/C<br>EI 90 C/C   |

**Table B2.2 PP pipes**

| Pipe material | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|---------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|               |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PP            | ≤ 40                  | 1.8                         | 60                   | see fig. 4 in Annex C | EI 120 U/C<br>EI 120 C/C |
|               | ≤ 50                  | 2.3                         | 60                   | see fig. 4 in Annex C |                          |
|               | ≤ 135                 | 6.0                         | 60                   | see fig. 4 in Annex C |                          |

**Table B2.3 PVC-U / PVC-C pipes**

| Pipe material    | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|------------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|                  |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PVC-U /<br>PVC-C | ≤ 40                  | 1.9                         | 60                   | see fig. 6 in Annex C | EI 120 U/C<br>EI 120 C/C |
|                  | ≤ 50                  | 2.0                         | 60                   | see fig. 6 in Annex C |                          |
|                  | 40 < Ø ≤ 140          | see fig. 5 in Annex C       | 60                   | see fig. 6 in Annex C |                          |
|                  | 110 < Ø ≤ 160         | see fig. 5 in Annex C       | 100                  | see fig. 3 in Annex C |                          |


**Piro Wrap PW**

**Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW**  
Plastic pipe penetration seal in rigid wall

**Annex B2**  
of European  
Technical Assessment  
ETA-17/1064



**Plastic pipe penetration seal in rigid floor, made with use of Piro Wrap PW.**



- 1 rigid floor thickness of  $B \geq 150$  mm
- 2 plastic pipe, diameter  $\varnothing$ , pipe wall thickness  $t$
- 3 Piro Wrap PW [ $l \times g$ ] mm, placed in the distance of  $d = 10$  mm from the bottom of the floor
- 4 space between the pipe and supporting construction filled with cement mortar,  $u \leq 25$  mm

**Piro Wrap PW**

**Construction details**

Plastic pipe penetration seal in rigid floor

**Annex B3**  
of European  
Technical Assessment  
ETA-17/1064

**Resistance to fire classification of plastic pipes penetration seals in rigid floor, made with use of Piro Wrap PW, in accordance with Annex B3.**

**Table B4.1 PE-HD / PE / ABS / SAN + PVC pipes**

| Pipe material                    | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|----------------------------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|                                  |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PE-HD /<br>PE / ABS /<br>SAN+PVC | ≤ 40                  | 2.7                         | 60                   | see fig. 8 in Annex C | EI 120 U/C<br>EI 120 C/C |
|                                  | ≤ 50                  | 3.5                         | 60                   | see fig. 8 in Annex C |                          |
|                                  | 40 < Ø ≤ 140          | see fig. 7 in Annex C       | 60                   | see fig. 8 in Annex C |                          |
|                                  | 140 < Ø ≤ 160         | see fig. 7 in Annex C       | 100                  | see fig. 9 in Annex C |                          |

**Table B4.2 PP pipes**

| Pipe material | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|---------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|               |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PP            | ≤ 40                  | 1.8                         | 60                   | see fig. 8 in Annex C | EI 120 U/C<br>EI 120 C/C |
|               | ≤ 50                  | 2.0                         | 60                   | see fig. 8 in Annex C |                          |
|               | ≤ 140                 | see fig. 10 in Annex C      | 60                   | see fig. 8 in Annex C | EI 90 U/C<br>EI 90 C/C   |
|               | 40 < Ø ≤ 135          | see fig. 10 in Annex C      | 60                   | see fig. 8 in Annex C | EI 120 U/C<br>EI 120 C/C |
|               | 110 < Ø ≤ 160         | see fig. 10 in Annex C      | 100                  | see fig. 9 in Annex C |                          |
|               | 135 < Ø ≤ 160         | see fig. 10 in Annex C      | 100                  | see fig. 9 in Annex C | EI 90 U/C<br>EI 90 C/C   |

**Table B4.3 PVC-U / PVC-C pipes**

| Pipe material    | Pipe diameter, Ø [mm] | Pipe wall thickness, t [mm] | Intumescent material |                       | Fire resistance class    |
|------------------|-----------------------|-----------------------------|----------------------|-----------------------|--------------------------|
|                  |                       |                             | width, l [mm]        | thickness, g [mm]     |                          |
| PVC-U /<br>PVC-C | ≤ 40                  | 1.6                         | 60                   | see fig. 8 in Annex C | EI 120 U/C<br>EI 120 C/C |
|                  | ≤ 50                  | 1.9                         | 60                   | see fig. 8 in Annex C |                          |
|                  | 40 < Ø ≤ 140          | see fig. 11 in Annex C      | 60                   | see fig. 8 in Annex C |                          |
|                  | 40 < Ø ≤ 160          | see fig. 11 in Annex C      | 100                  | see fig. 9 in Annex C |                          |


**Piro Wrap PW**

**Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW**  
Plastic pipe penetration seal in rigid floor

**Annex B4**  
of European  
Technical Assessment  
ETA-17/1064



**Fig. 1. Range of PE-HD / PE / ABS / SAN + PVC pipes penetration sealed with use of Piro Wrap PW (width of 100 mm), made in accordance with Annex B1.**




**Piro Wrap PW**

**Resistance to fire classification of penetration seals made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064

Fig. 2. Range of intumescent material thickness for PE-HD / PE / ABS / SAN + PVC pipes penetration sealed with use of Piro Wrap PW (width of 60 mm), made in accordance with Annex B1.

l – intumescent material width, g – intumescent material thickness




|  |  |  |
|--|--|--|
| <b>Piro Wrap PW</b>  |  | <b>Annex C</b><br>of European<br>Technical Assessment<br>ETA-17/1064 |
| <b>Resistance to fire classification of penetration seals<br/>made with use of Piro Wrap PW</b><br>Ranges of pipes diameter, pipes walls thicknesses and intumescent<br>material thickness |  |  |



**Fig. 3. Range of intumescent material thickness for PE-HD / PE / ABS / SAN + PVC pipes penetration sealed with use of Piro Wrap PW (width of 100 mm), made in accordance with Annex B1.**

**l – intumescent material width, g – intumescent material thickness**



**Piro Wrap PW**


**Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent  
material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064



**Fig. 4. Range of intumescent material thickness for PP pipes penetration sealed with use of Piro Wrap PW (width of 60 mm), made in accordance with Annex B1.**

*l* – intumescent material width, *g* – intumescent material thickness




#### Piro Wrap PW

#### Resistance to fire classification of penetration seals made with use of Piro Wrap PW

Ranges of pipes diameter, pipes walls thicknesses and intumescent material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064


Fig. 5. Range of PVC-U / PVC-C pipes penetration sealed with use of Piro Wrap PW (width of 60 and 100 mm), made in accordance with Annex B1.



|  |  |  |
|--|--|--|
| <b>Piro Wrap PW</b>  |  | <b>Annex C</b><br>of European<br>Technical Assessment<br>ETA-17/1064 |
| <b>Resistance to fire classification of penetration seals<br/>made with use of Piro Wrap PW</b><br>Ranges of pipes diameter, pipes walls thicknesses and intumescent<br>material thickness |  |  |



**Fig. 6. Range of intumescent material thickness for PVC-U / PVC-C pipes penetration sealed with use of Piro Wrap PW (width of 60 mm), made in accordance with Annex B1.**  
l – intumescent material width, g – intumescent material thickness




**Piro Wrap PW**

**Resistance to fire classification of penetration seals made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064

Fig. 7. Range of PE-HD / PE / ABS / SAN + PVC pipes penetration sealed with use of Piro Wrap PW (width of 60 and 100 mm), made in accordance with Annex B3.



Piro Wrap PW


Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW  
Ranges of pipes diameter, pipes walls thicknesses and intumescent  
material thickness

Annex C  
of European  
Technical Assessment  
ETA-17/1064



**Fig. 8. Range of intumescent material thickness for PVC-U / PVC-C, PE-HD / PE / ABS / SAN + PVC and PP pipes penetration sealed with use of Piro Wrap PW (width of 60 mm), made in accordance with Annex B3.**

**l – intumescent material width, g – intumescent material thickness**




|  |  |  |
|--|--|--|
| <b>Piro Wrap PW</b>  |  | <b>Annex C</b><br>of European<br>Technical Assessment<br>ETA-17/1064 |
| <b>Resistance to fire classification of penetration seals<br/>made with use of Piro Wrap PW</b><br>Ranges of pipes diameter, pipes walls thicknesses and intumescent<br>material thickness |  |  |



**Fig. 9. Range of intumescent material thickness for PVC-U / PVC-C, PE-HD / PE / ABS / SAN + PVC and PP pipes penetration sealed with use of Piro Wrap PW (width of 100 mm), made in accordance with Annex B3.**

**l – intumescent material width, g – intumescent material thickness**




**Piro Wrap PW**

**Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent  
material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064

Fig. 10. Range of PP pipes penetration sealed with use of Piro Wrap PW (width of 60 and 100 mm), made in accordance with Annex B3.




#### Piro Wrap PW

**Resistance to fire classification of penetration seals made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064



**Fig. 11. Range of PVC-U / PVC-C pipes penetration sealed with use of Piro Wrap PW (width of 60 and 100 mm), made in accordance with Annex B3.**



**Piro Wrap PW**

**Resistance to fire classification of penetration seals  
made with use of Piro Wrap PW**  
Ranges of pipes diameter, pipes walls thicknesses and intumescent  
material thickness

**Annex C**  
of European  
Technical Assessment  
ETA-17/1064

