

TABLE FOR SELECTING THE NUMBER OF WRAPS OF PIRO MULTITUBE PM FOR METAL PIPE IN PE INSULATION WITH A CABLE

COPPER PIPES					
	Select the type of Piro Multitube PM		FLOOR EI 120 width from 150 mm and density 1700 kg/m ³		
Insulation thickness 9 mm					
Nominal pipe diameter, maximum wall thickness 14.2	Piro Multitube PM width selected from ETA	Piro Multitube PM thickness selected from ETA	Number of rows of Piro Multitube PM	Number of Piro Multitube PM wraps	Length of the tape to be cut off
mm	mm	mm			mm
DN ≤ 22,2 + kabel ≤ 14 mm	60	2,5	1	2	Depending on the diameter
	60	4	1	1	
	100	4,8	1	1	