FLOOR CLASS EI 180 width min. 150 mm density 1700 kg/m 3

a) Quadruple heating pipe Syncopex C.O. PN6 / 95 C, C.W. PN10 / 70C - PE-X pipes with dimensions: 50 x 3.0 mm, 32 x 2.5 mm, 20 x 2.1 mm and 50 x 5.0 mm (max.diameter x constant thickness of pipe wall)
b) 32 mm thick PE insulation placed in a corrugated PE-HD pipe with a max. 160 mm diameter and 0.5 mm pipe wall thickness
c) Piro Multitube PM (in accordance with ETA-17/1061) with dimensions of 9.6 x 100 mm (thickness x width)
d) Dimensions of the intumescent material: 16.0 x 60 mm (thickness x width)